

## Guidance note 3: Initial verification and periodic inspection of electrical installations

### ATTENTION TO ALL WIREMEN

The IEE Wiring Regulations require an initial verification report to be compiled by the installer indicating that the installation has been tested and is compliant to BS7671. Periodic inspection and testing is then a responsibility of the user or owner of the installation, however the I.E.E. Regulations require that the person carrying out the initial verification shall make a recommendation for subsequent periodic inspection and testing. The period between inspections is recommended in the IEE Guidance Note 3, according to the type of building. Inspection and testing must also be performed by a licensed person, who must then recommend the time of the next inspection and the repairs, extensions and modifications that may be required, indicating their urgency.

The MRA would like to draw your attention to this recommendation which aims at ensuring that electrical installations are kept in safe working conditions.

Furthermore it is also recommended that a copy of the initial test certificates and periodic inspection certificates are given to the owner of the installation for record keeping.

**Disclaimer:**

These guidelines do not supersede the I.E.E. Regulations (BS 7671) and its subsequent amendments. The Malta Resources Authority does not assume any liability to any person for any loss or damage caused by way of error or omission whether this has occurred through negligence or any other cause.



## Nota Gwida numru 3: Verifika Inizjali u Spezzjoni Perjodikali ta' Installazzjoni ta' I-Elettriku

### AVVIŻ LIL KULL 'WIREMAN'

Ir-Regolamenti ta' l-I.E.E. dwar il-Wiring' jeħtiegu li jsir rapport ta' verifika mill-installatur kif l-installazzjoni tkun kompluta. Tali rapport irid jindikar illi l-installazzjoni għet ittestjata skond ma jipprovdu r-Regolamenti tal-BS7671. Spezzjonijiet perjodikali u 'testing' sussegwenti jaqgħu taħt ir-responsabbiltà ta' dak li jkun qed jagħmel użu minn jew tas-sid ta' dik l-installazzjoni. Izda, ir-Regolamenti ta' l-I.E.E. jeħtiegu li l-persuna li tkun għamlet il-verifika fil-bidu għandha tagħmel rakkomandazzjoni għall-spezzjonijiet u 'testing' sussegwenti. Il-perjodu bejn spezzjoni u oħra huwa rakkomandat fil-Gwida Nota numru 3 ta' l-IEE, u dan jiddependi mit-tip ta' bini. L-ispezzjonijiet u t-'testing' għandhom ukoll jiġu magħmula minn persuna li jkollha l-licenzja li twettaq dan, illi din mbagħad trid tirrakkomanda iż-żmien ta' l-ispezzjoni li jmiss, tattiswijiet, ekstenzjoni u modifikazzjonijiet li jkun hemm bżonn, skond l-urgenza tagħhom.

L-MRA tixtieq għalhekk, tigbed l-attenzjoni ta' l-installaturi għal din ir-rakkomandazzjoni li l-għan tagħha huwa li tiżgura illi l-installazzjonijiet ta' l-elettriku qed jinżammu f'kundizzjonijiet siguri.

Barra minnhekk, qed jiġi rakkomandat illi għandhom jingħataw kopji taċ-ċertifikati ta' l-ewwel testijiet ta' l-installazzjonijiet u ta' l-ispezzjonijiet perjodikali lis-sid ta' l-installazzjoni u dan għall-fini sabiex jinżammu r-records kollha.

#### Dikjarazzjoni:

Dawn il-linji gwida ma jissuperawx ir-Regolamenti ta' l-I.E.E. dwar il-Wiring (BS 7671) u l-emendi sussegwenti ta' dawn ir-regolamenti. L-Awtorità ta' Malta dwar ir-Riżorsi (MRA) mhix responsabbli fil-konfront ta' kwalunkwe persuna għal xi telf jew ħsara kkaġunata lil tali persuna minħabba xi żball jew xi

